

FIBER SEGMENT CONTINUITY AND LOSS REPORT

Project Name: Cleanwater Services
OM3 Fiber Cabling
Tested by: Kellen Heidrick & Kody Elliott-Heidrick **Date:** 1/19/2022

Test Location: **Cabinet 1**

| <u>Port No.</u> | <u>Continuity (Y or N)</u> | <u>End Location</u> | <u>Loss (dB) 850nm</u> | <u>Loss (dB) 1300nm</u> |
|-----------------|--------------------------------|---------------------|----------------------------|-----------------------------|
| 1 | Y | Cabinet 2 Port 1 | 0.21 | 0.25 |
| 2 | Y | Cabinet 2 Port 2 | 0.3 | 0.31 |
| 3 | Y | Cabinet 2 Port 3 | 0.17 | 0.29 |
| 4 | Y | Cabinet 2 Port 4 | 0.17 | 0.2 |
| 5 | Y | Cabinet 2 Port 5 | 0.36 | 0.26 |
| 6 | Y | Cabinet 2 Port 6 | 0.32 | 0.3 |
| 7 | Y | Cabinet 2 Port 7 | 0.23 | 0.21 |
| 8 | Y | Cabinet 2 Port 8 | 0.19 | 0.24 |
| 9 | Y | Cabinet 2 Port 9 | 0.33 | 0.34 |
| 10 | Y | Cabinet 2 Port 10 | 0.22 | 0.29 |
| 11 | Y | Cabinet 2 Port 11 | 0.19 | 0.20 |
| 12 | Y | Cabinet 2 Port 12 | 0.18 | 0.18 |